IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Santa May DATE 5-15-81 PERMIT NO. 139

PHONE: Business _____ Home _____

LOCATION 1303 N. NC. 1300 1st rd. to Rt. past jct. w/ 1398 (FAIRBURN LANE) 2nd lot on Rt. S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 122 SECTION OR BLOCK NO. 15

House (✓) Mobile Home ( ) Business ( ) Other BOAT


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil loamy parent material
Percolation Rate 30 mpi
Topography 15-25%
Depth to Water Table 10'+
Rock or other impervious formations none obs.

Lot Area ~ 3/4 Ac.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. _____ Linear Ft. ~100 of perfs
Depth of Stone in Lines 9" sand below
Water Supply: Individual (✓) Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 5-15-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold