4638085679

The proposed / existing ADDITION addition does not appear to impact the existing septic system.

IREDELL CO **NOTE: R-A 2003 ROS REHS

(SEPTIC TANK) IMPROVEMENT SEE ATTACHED Date: 6-1-100
(Ground Absorption Sewage D ICHD-Environmental Health Division

OWNER OR CONTRACTOR Charles J. Borawa DATE July 20, 1988 PERMIT NO.

PHONE: Business 373-8032 Home

LOCATION Perth Rd. N. TL Fern Hill Pass Periwinkle 2nd R. (Fairburn Dr. - unmarked) On R S. R. No.

SUBDIVISION NAME LOT NO. 995 SECTION OR BLOCK NO.


House ( ) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	~ 20%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none observed

Lot Area 1.9 ACRE

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System NOT TO SCALE

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines ~~4~~ 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY ~~ACP~~

COMMENTS:

CERTIFICATE OF COMPLETION BY Andrew C. Pierce DATE 7/20/88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold