4638-08-5679

The proposed / existing ADDITION [redacted]
addition does not appear to impact the existing septic system.

IREDELL CO **NOTE: _____

(SEPTIC TANK) IMPROVEMENT See Attached
(Ground Absorption Sewage D

R. Allen REHS
Date: 6-1-100
ICHD-Environmental Health Division

OWNER OR CONTRACTOR Charles J. Borawa DATE July 20, 1988 PERMIT NO. _____

PHONE: Business 373-8032 Home _____

LOCATION Perth Rd. N. TL Fern Hill Pass Periwinkle 2nd R. (Fairburn Dr. - unmarked) On R S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 995 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 3
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clay
Percolation Rate .4
Topography ~ 20%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area 1.9 ACRE

LAKE

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System NOT TO SCALE

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ~~ACP~~

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andre C. Pierce DATE 7/20/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold