IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James F. Edwards DATE 3-28-79 PERMIT NO. 75

PHONE: Business _____ Home 803-528-4664

LOCATION 1303 to 12 on 1500 Then right across bar 1398 .3 mi on Left S. R. No. _____

SUBDIVISION NAME L-N LOT NO. 126 SECTION OR BLOCK NO. 15


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area .96ac

Character & Porosity of Soil Sandy Parent Materials
Percolation Rate 60 min/in
Topography 15%
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 400 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY David Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 5-29-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold