IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ronald C. Raw DATE 8-6-79 PERMIT NO. 270

PHONE: Business _____ Home _____

LOCATION 1303 N TL on 1300 TR across from Kennedy Dr. (1398) left at forks ¼ mi. on left

SUBDIVISION NAME L.V. LOT NO. 127 SECTION OR BLOCK NO. 15 S. R. No. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil sandy gravel material
Percolation Rate 50 min/in
Topography 5-25%
Depth to Water Table 6'+
Rock or other impervious formations none obs.

Lot Area ~3/4 AC.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 6"+
Water Supply: Individual (✓)
Public ( )

Installed by Lee Lackey

IMPROVEMENTS PERMIT BY M. R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Ronald C. Hinson DATE 8-6-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold