ADDENDUM TO FRANK N. FARRELL IMPROVEMENT PERMIT

PUMP SPECS-SUPPLY LINE

-GREATER THAN 27 FEET ELEVATION HEAD REQUIRED
-NO LESS THAN 125 FEET TRAVEL THRU SCH 40 PVC, 2" ID, ALL JOINTS GLUED
-DUCTILE IRON OR GREATER REQUIRED UNDER WALL AND DRIVE-PARK AREA
-NO MORE THAN 130 GALS. PER DOSE
-2 FOOT PRESSURE HEAD REQUIRED IN EACH LATERAL OF DRAINFIELD-STAND PIPES REQUIRED
-ALL VALVES AND STAND PIPES IN VALVE BOXES WITH COVER-SET EVEN WITH FINISHED GRADE
-DRAWING ALLOWS FOR EASIEST ACCESS TO REPAIR/EXPANSION AREA; NO VARIATION WITHOUT ICHD APPROVAL

DRAINFIELD

-240 FEET 16" PREFAB. PERMEABLE PANEL BLOCKS, 55 PANELS REQUIRED
-TRENCHES INSTALLED ON CONTOUR-LEVEL GRADE ON TRENCH BOTTOM
-MAXIMUM TRENCH DEPTH OF 36"
-1¼" PVC THRU PANELS WITH A 3/16" HOLE CENTERED IN EACH PANEL
-HOLE MAY BE TURNED UP INSIDE EACH PANEL BLOCK