IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Johnny L. Swartz DATE 11-22-83 PERMIT NO. 401

PHONE: Business _____ Home _____


LOCATION 150 W R1396 (Rustic Lane) 3/4 mile N to East Lake Valley Road

SUBDIVISION NAME East Lake S/D LOT NO. 7 SECTION OR BLOCK NO. _____ S. R. No. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3½

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	0.5 gpf
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Hillside 5%
Site Suitable	Yes (X)	No ( )	Depth to Water Table	4+ ft
Lot Area 1 acre			Rock or other impervious formations	None observed



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 120 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by Donald Hartley

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: OK August Change

CERTIFICATE OF COMPLETION BY Fred Clemmer

EXISTING SYSTEM CHECKED BY: _____ DATE 11-22-83

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold