4638117635

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jim Baity DATE 9-30-82 PERMIT NO. 303

PHONE: Business _____ Home _____

LOCATION 150W TR 1356 ~ ½ mile TL on R

S. R. No. _____

SUBDIVISION NAME WestLake Valley LOT NO. 5 SECTION OR BLOCK NO. _____


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes (X) No ( )
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )
Lot Area ½ ACRE

Character & Porosity of Soil Clay loam
Percolation Rate 0.5 mpi
Topography 6-8% slope
Depth to Water Table Unknown
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 740 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by Ross Perkins

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Daniel R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 9-30-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold