IREDELL COUNTY HEALTH DEPARTMENT 4638118480

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James H. Baity DATE 12-21-83 PERMIT NO. 435

PHONE: Business _____ Home _____

LOCATION 150 W TR 1396 ½ mile TL Rustic Lane on left

S. R. No. _____

SUBDIVISION NAME EAST LAKE Valley S/D LOT NO. 11 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	
Auto. Dishwasher	Yes (X)	No ( )	
Auto. Wash. Machine	Yes (X)	No ( )	
Site Suitable	Yes (X)	No ( )	

Lot Area 32,805 ft²

Character & Porosity of Soil Clay loam/gravelly
Percolation Rate 0.6 gpd/ft²/day
Topography Rolling
Depth to Water Table 4'+
Rock or other impervious formations None obs

X No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by J. J. Erwin Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY David Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Janet Clemmer DATE 12-21-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold