SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

ER: Eric Hausfield APPLICANT: _____

DRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/7/04

POSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____

ATION OF SITE: Robinson PROPERTY RECORDED: _____

TER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

LUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut

E OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
Pit 1	0-10"	Brw/Rd CL	m-w SBK	SS, SP, SE, PR	Some SAP Inclos			PS .3+
	10-34"	L/CL w/few to many	SAP Inclos/Common Mica					
	34"-50	Rd/Brw to Yel/Red	L/SL	SAP				
AH-1	0-12"	Brw/Rd CL	m-w SBK	SS, SP, SE, PR	Some SAP			PS .3+
	12"-34"	L/CL	w/few to many	SAP Inclos	Common Mica Flakes			
	34"-50"	Rd/Brw to Yel/Red	L/SL	SAP				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
uble Space (.1945)		
n Type(s)		
TAR		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____

OTHER(S) PRESENT: _____