DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: William Merritt APPLICANT: ___
ADDRESS: 144 N. Shore Dr. APPLICATION DATE: ___ DATE EVALUATED: 8-16-05
PROPOSED FACILITY: Residential PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.66 Ac
LOCATION OF SITE: 150 W TR Robinson Rd. Lot 1 PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
pit 1	5%	0-25	2 sbk/vfabk cl	fr ss/sp se		48			PS .3
		25-48	1 sbk/vfabk cl + sap	fr ss/sp se					
2		0-23	1 sbk/vfabk cl	fr ss/sp se		48			PS .3
		23-48	1 sbk/vfabk cl + sap	fr ss/sp se					
3	Possible Repair upper rt. corner	0-28	1 sbk/vfabk cl	fr ss/sp se		35			50' from well
		28-35	1 sbk/vfabk c + sap	fr ss/sp se					
		35+	sap						
4	5%	0-25	1 sbk/vfabk cl	fr ss/sp se					
		25-48	1 sbk/vfabk cl + sap						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Yes	Yes
System Type(s)	LP Panel	LP Panel
Site LTAR	.3	

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Judy Melville
OTHER(S) PRESENT: ___