4638-17-1866

IREDELL COUNTY HEALTH DEPARTMENT

1380

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas Graham DATE April 18, 1990 PERMIT NO. 25-5-A-72

PHONE: Business _____ Home _____

LOCATION 150 W TR Perth TL Fernhill TL Broadview 1st trailer on left. S. R. No. _____

SUBDIVISION NAME CLEAR LOT NO. 72 1012 SECTION OR BLOCK NO. 15

House ( ) Mobile Home (✓) Business ( ) Other ~~Existing~~ See permit Jerry Furr 1989

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil _____

Percolation Rate _____

Topography _____


Depth to Water Table _____

Rock or other impervious formations _____

Lot Area 1.69 ac

V +50'

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Broadview Plot of System

Size of Tank Existing Gals.

Nitrification Field:

No. of Lines _____

Sq. Ft. _____ Linear Ft. 195'

Depth of Stone in Lines 18"

Water Supply: Individual ( ) Public ( )

Panel

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: See permit Jerry Furr 9858 25-5-A-72 Finaled Aug 89
System appears to be functioning properly at time of inspection due only to no effluent noted on the surface of the ground.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Sam Ingram EH-S DATE Apr 18, 1990

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold