IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Brown DATE 8-6-76 PERMIT NO. 207

PHONE: Business _____ Home _____

LOCATION 1200 East Fork Hill Church Rd 2nd Kennedy Dr Turn Left 1st Right 1st mi on Left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 76 SECTION OR BLOCK NO. 15


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 acre

Character & Porosity of Soil Sandy Clay loam Loose to Fair
Percolation Rate 60 T to the Inch
Topography Slope 5 to 8%
Depth to Water Table 10 ft
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hobbs Brothers Septic Tank

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 8-6-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold