4638-17-3426

Type 4 Insp
2-12-2002

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR GREG LEWIS / Denver Dawson DATE 3/23/88 PERMIT NO. _____

PHONE: Business 125 Broadview Home 523-8668 (704) 528-2381

LOCATION 150 W TR Perth Rd. TL Fern Hill TL 1st Broadview Lp. (formerly St Charles Ln) 3rd lot on L. S. R. No. _____

SUBDIVISION NAME Crescent Land & Timber LOT NO. 1010 SECTION OR BLOCK NO. 15


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	~ 4 gpd/ft²
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	8→10%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none observed

Lot Area .89 ACRE

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement P. Tank 1250 gals



Plot of System NOT TO SCALE

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Wayne Potts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andre C. Pierce

COMMENTS: CK High water alarm →
Tanks, lines, pressure head on lines OK 3/23/88

CERTIFICATE OF COMPLETION BY Andre C. Pierce DATE 4/14/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold