7624

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR GREG LEWIS DATE 11/6/87 PERMIT NO.

PHONE: Business Home 523-8668

LOCATION 150 W. TR, PERTH RD. T.L. FERN HILL RD. T.L. 1st BROADVIEW LP. (FORMERLY St. CHARLES) 3RD LOT ON LEFT. S. R. No.

SUBDIVISION NAME C L & T LOT NO. 1010 SECTION OR BLOCK NO. 15

~~FUTURE~~ Temporary

House (✓) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2


Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clayey
Percolation Rate 4 gpd/ft²
Topography 8-10%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area .89 ACRE

____ Basement with Plumbing ____ Basement without Plumbing ✓ No Basement

PUMP TANK 1250



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Gregory D. Lewis

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: Set tanks 50' from HIGH WATER MARK. PUMP EFFLUENT TO A MODIFIED CONVENTIONAL DRAINFIELD. (SOLID PIPE (1½) IN DITCH W/ 3/32" hole every 5'). USE LARGE ENOUGH PUMP TO ACHEIVE 2' head in each ditch. CALL HEALTH DEPT FOR SPECS. (664-5281 b/n 8-9AM.)

~~CERTIFICATE OF COMPLETION~~ BY DATE

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold