IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Brown DATE 8-8-75 PERMIT NO. 184

PHONE: Business _____ Home 873-4687

LOCATION 1303 on Tr. on 1300 Tr. on 1398
1st Drive To Right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 66 SECTION OR BLOCK NO. 15


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Sandy Clay loam Porous Fair
Percolation Rate Not Taken
Topography 2 2½ Slope
Depth to Water Table 10 ft Lake Level
Rock or other impervious formations None

Lot Area 3 acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 425 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Yount Septic Tank

IMPROVEMENTS PERMIT BY John Lowrance

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Lowrance DATE 8-8-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold