IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 Princeton Bld. MOORESVILLE 704-664-5281 1.00

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # ~~166743~~ 72015 PIN # 4638 18 6819 DATE June 10, 2011

OWNER or APPLICANT Woodbridge Partners LLC PHONE: Business 704-799-9770 Home:

OWNER or APPLICANT ADDRESS PO Box 3608 Mooresville NC 28117

LOCATION / DIRECTIONS Perth Rd N. TL Fern Hill TL 2nd Kenway Loop on corner

SUBDIVISION Fernleaf BLOCK / SECTION 2 LOT # 31 LOT AREA .748 Ac. DESIGN FLOW 480gpd L.T.A.R. .3gpd/ft²

Septic Tank 1000 Gallons: STB 1012 Date 2-23-12 ☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

Pump Tank Gallons: PT Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 4 Linear Feet 400

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA ☒ GRAVITY ☐ PRESSURE

System Description: 2590 Reduction gravity

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ Residence No. Bedrooms 4 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions 4/16/2016 Renewal Floor plans & Site plan in Compliance with original permit (Reverse Floor plans)

INITIAL SITE SKETCH

See Plan from Kathleen Saunders, LSS
Approved by ICHD

Comments / Conditions 5/21/2012 Installed Quick 4 (did not use separate "drop boxes") fed into top of chamber. Installed as Drawn.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☒ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Kathleen Saunders Date 6/13/11

Improvement Permit by: [illegible] REHS Date 6-10-11

Authorization to Construct by: [illegible] RS Date 4/16/12

Installed by: Gunter Grading LLC

Operation Permit by: [illegible] Date 5/21/12

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant