3:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 131890 PIN# 4638 19 9433 DATE Nov. 9, 05

OWNER OR APPLICANT Nations Land Co, LLC / BEAK BUILDERS PHONE: Business 330-832-4691 Home

ADDRESS 4330 Sterilite St, SE Massillon, OH 44646

LOCATION 150 W TR Peach Rd (N) TL Fern Hill on Right approx 200yds before jct w/ Bridlewood DR.

SUBDIVISION Lakewood Crossing BLOCK / SECTION LOT 4 LOT AREA .78Ac SITE CLASS. 5 DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 625 Date 10/24/06

Pump Tank: 1000 Gallons; PT 302 Date 10/25/06

Pump Make: Zoeller Model N152B Serial No. 11/2006

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4@100' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I, II, (III)B, IV, V, VI

System Description: Pm 25% Reduction

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☐ Yes ☒ No Initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons ___ No. Employees ___

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Initial site evaluation and system design performed by Rollins Soil & Env. Services

Comments:/Conditions: Pressure manifold, drip tubing installed

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Terry Edmondson date 11-10-05

Improvement Permit by: [signature] date 11-9-05

Authorization to Construct by: Judy Melville date 4-25-06

Installed by: Rowan Septic Tank

Operation Permit by: Wesley Sparks RS date 3/22/07

Existing System Inspection by: ___ date ___

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK