IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13892 PIN# 4638199664 DATE Nov. 10, 05

OWNER OR APPLICANT Nations Land 6, LLC / Paul Simionescu PHONE: Business 330-832-4091 Home

ADDRESS 4330 Sterkate St. SE, Massillon, OH 44646

LOCATION 150 W TR Teeth Rd (R) TL Ferry Hill on Right ~400' past Periwinkle Cir.

SUBDIVISION Lakewood Crossing BLOCK / SECTION LOT 6 LOT AREA ~.92Ac SITE CLASS. PS DESIGN FLOW 440gpd L.T.A.R. .03

Septic Tank: 1000 Gallons; STB 114 Date 12-20-06
Pump Tank: 1000 Gallons; PT 333 Date 11-19-06
Pump Make: Gould's Model WE0-712 Serial No.
Nitrification Field: No Fields 1 Square Feet 584 Linear Feet *292
No Lines 4 Trench Width * Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LPPPBS
Repair System Description: LPPPBS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons
☐ Business No. Employees
☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: * SEE PLAN SPECS

Initial site evaluation and system design performed by Rollins Soil & Env. Services

Comments:/Conditions:

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

4 Lines Installed of ~~5~~ Panel

Top line = 87'
2nd " = 87
3rd " = 77'
4th " = 53'

304 Total L.F.A.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Regis Suttz date 11-14-05 Installed by: C & S Grading

Improvement Permit by: DM Hinson RS date 11-10-05 Operation Permit by: date 6-11-07

Authorization to Construct by: Judy McCully date 8-2-06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK