IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Frederick P. Shiffley DATE 1/25/89 PERMIT NO. 17 D

PHONE: Business _____ Home _____

LOCATION 150 W. TR 1303 (Perth Rd.) TL Normandy Rd. at end on R. S. R. No. _____

SUBDIVISION NAME C L and T LOT NO. 153 (County #) SECTION OR BLOCK NO. 11

Future temporary

House (✓) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 4

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay class IV A
Percolation Rate 5.4
Topography 6-10%
Depth to Water Table 4'+
Rock or other impervious formations None observed

Lot Area 1 ACRE+

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement (ACP)



Plot of System NOT TO SCALE.

1500 gal Pump Tank

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1215 Linear Ft. 405
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

LAKE NORMAN

Installed by Roddi Long Gadding (Denver, N.C.)

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

DRIVE

IMPROVEMENTS PERMIT BY DRH

COMMENTS: System inspected by DRH. Pump and alarm checked by ACP -- 1/25/89

CERTIFICATE OF COMPLETION BY Andrie C. Pierce DATE 1/25/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold