IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Anderson DATE 7-19-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1303 Th on 1428 near end of Rd on right

SUBDIVISION NAME Lake Norman LOT NO. 149 SECTION OR BLOCK NO. 4


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes ( )	No (✓)
Site Suitable	Yes (✓)	No ( )

Lot Area 1.89 acres

Character & Porosity of Soil Clay loam Brosity Fair
Percolation Rate Not taken
Topography 2-3% Slope
Depth to Water Table 10' +
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Don Lackey

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. C. Moore DATE 7-19-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold