DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES

SITE / SOIL EVALUATION
FOR
SANITARY SEWAGE SYSTEM

OWNER: Jeff Hoyt PHONE: _____ DATE REQUESTED: _____ DATE EVALUATED: _____

ADDRESS: _____ PROPERTY IDENTIFICATION NO.: _____

COUNTY: _____ PROPERTY SIZE: .63 PROPOSED FACILITY: 3 bdrm SFD

LOCATION OF SITE: Lot 2 Normandy Hills

WATER SUPPLY: On-Site Well ✓ Community _____ Public _____ EVALUATION BY: Auger Boring X Pit _____ Cut _____

FACTORS	PROFILE 1	PROFILE 2	PROFILE 3	PROFILE 4	PROFILE 5
LANDSCAPE POSITION	LS	LS			
SLOPE (%)	7-9%	11			
HORIZON I DEPTH	0-10	0-9			
Texture Group	cl	cl			
Consistence	FR SS SP	VFR - NS - NP			
Structure	SBK	GR.			
Mineralogy	1:1	1:1			
HORIZON II DEPTH	11-25	10-31			
Texture Group	sa cl	sa cl			
Consistence	FR SS NP	FR SS - SP			
Structure	Fi SBK	Fi sbk			
Mineralogy	1:1	1:1			
HORIZON III DEPTH	26-49	32-48			
Texture Group	cl SAP	cl sap			
Consistence	FR SS NP	VFR. SS - NP			
Structure	GR	SBK - MICA			
Mineralogy	1:1	1:1			
HORIZON IV DEPTH					
Texture Group					
Consistence					
Structure					
Mineralogy					
SOIL WETNESS					
RESTRICTIVE HORIZON					
SAPROLITE					
CLASSIFICATION					
LONG-TERM ACCEPTANCE RATE					

SITE CLASSIFICATION: PS

EVALUATED BY: Sparks

SITE LONG-TERM ACCEPTANCE RATE: .3

OTHER(S) PRESENT: None

REMARKS: Highly topo and rock out crop on front of lot and to be avoided with septic system.

LEGEND

LANDSCAPE POSITION
- R - Ridge
- S - Shoulder slope
- L - Linear slope
- FS - Foot slope
- N - Nose slope
- H - Head slope
- Cc - Concave slope
- Cv - Convex slope
- T - Terrace
- FP - Flood Plain

TEXTURE
- s - sand
- ls - loamy sand
- sl - sandy loam
- l - loam
- si - silt
- sil - silt loam
- sicl - silty clay loam
- cl - clay loam
- scl - sandy clay loam
- sc - sandy clay
- sic - silty clay
- c - clay

CONSISTENCE

MOIST
- vfr - very friable
- fr - friable
- fi - firm
- vfi - very firm
- efi - extremely firm

WET
- Ns - non-sticky
- Ss - slightly sticky
- S - sticky
- Vs - very sticky
- Np - non-plastic
- Sp - slightly plastic
- P - plastic
- Vp - very plastic

STRUCTURE
- sg - single grain
- m - massive
- cr - crumb
- gr - granular
- sbk - subangular blocky
- abk - angular blocky
- pl - platy
- pr - prismatic

MINERALOG
1:1, 2:1, mixe

Use the above standard abbreviations.

NOTES:
- Horizon Depth -- In inches
- Depth of Fill -- In inches from land surface
- Restrictive Horizon -- thickness and inches from land surface
- Saprolite -- S (suitable) or U (unsuitable)

NOTES:
- Soil Wetness -- Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less -- record Munsell color chip designation
- Classification -- S (suitable), PS (provisionally suitable) or U (unsuitable)
- Long-Term Acceptance Rate -- gal/day/ft²

DHS 2601 (Revised _____)