4638275627

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Sandlin DATE 11-15-78 PERMIT NO. 282

PHONE: Business _____ Home _____

LOCATION 1303 T2 on 1300 T2 on 1398 at end of Pavement on Right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 55 SECTION OR BLOCK NO. 15


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No	(✓)
Auto. Dishwasher	Yes ( )	No	(✓)
Auto. Wash. Machine	Yes (✓)	No	( )
Site Suitable	Yes (✓)	No	( )

Lot Area .68 ac

Character & Porosity of Soil Clay loam
Percolation Rate 60 min/in
Topography 2% Slope
Depth to Water Table 6' to 8'
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Gibson

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 11-15-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold