owes Ø

# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 155584 PIN # 4638289368.000 DATE 3/23/09

OWNER or APPLICANT ~~Woodbridge Partners LLC~~ Heritage Bld PHONE Business 704 799-9770 Home:

OWNER or APPLICANT ADDRESS PO Box 3608 Mooresville NC 28117

LOCATION / DIRECTIONS Perth Rd (N) TL Fern Hill Rd TL Kenway Lp on (R)

SUBDIVISION Fernleaf BLOCK / SECTION LOT # 11 LOT AREA .849 DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank 1000 Gallons: STB 1007 Date 2-15-09

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 3 Linear Feet 402'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI

System Description: Gravity 25% Reduction LP PPBPS

Repair System Description:

Maintenance Agreement Required ☐ YES ☑ NO

☑ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☑ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions Lot requires some shaping to remove old field terraces, Knock down high spots do not fill Drainfield area.

Comments / Conditions 10/12/09 Reviewed Floor plans, in compliance with Orginal permit

INITIAL SITE SKETCH

Plumbing must be set for gravity flow or a LPP pump will be required.

See Plan by S&ME

SC 133' INSTALLED AS SHOWN

Plat submitted. Non-expiring IP

AS BUILT SKETCH

BUILDER SIG FOR MOVING TANK

*Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.*

☑ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☑ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Kathleen Saunders Date 3/27/09

Improvement Permit by: Anthony Coker L.R.S. Date 3/23/09

Authorization to Construct by: [signature] R.S. Date 10/12/09

Installed by: WAYNE CLONTZ

Operation Permit by: [signature] REHS Date: 4-7-10

Existing System Inspected by: [signature] Date: 4-7-10

***YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.***

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant