DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: 9/20/96 DATE EVALUATED: 10/10/96 (21)
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: NORMANDY RD #666 - LOT 146
WATER SUPPLY: On-Site Well X Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

| PROFILE # | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN.) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1948 CLASS OF HORIZ | 1943/ 1956 SAPRLT CLASS. | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | CVL | 0-6 | WK SBK / h scl | 1:1 FI S SP | | | | | |
| | | 7-16 | WK SBK / scl | 1:1 FR S SP | | | | | |
| | | 17-25 | GR / cl SAP | 1:1 FR SS SP | | | | | |
| | | 26-43 | GR / l SAP | 1:1 VFR SS SP | | | | | .3 |
| | | | | | | | | | |
| 2 | CVL | 0-6 | wk sbk / hcl | 1:1 / FR S SP | | | | | |
| | | 7-19 | SBK / cl m | 1:1 / FR S P | | | | | |
| | | 20-25 | SBK / cl | 1:1 / FR S P | | | | | |
| | | 26-44 | GR / sl SAP. | 1:1 / VFR SS NP | | | | | .3 |
| | | | | | | | | | |
| 3 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 4 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 5 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

AVAILABLE SPACE (.1945) SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE:
EVALUATED BY: SPARKS OTHER(S) PRESENT: RICH PIZZO
COMMENTS: Well - home location