IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Hale DATE May 17, 79 PERMIT NO. 145

PHONE: Business _____ Home _____


LOCATION 150W TR on 1303 T.L. on 1428 2.3 mi. on Rt _____ S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 140 SECTION OR BLOCK NO. 11

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1.86 AC.

Character & Porosity of Soil Cecil Clay loam
Percolation Rate 80 mpi +
Topography 4-8%
Depth to Water Table 4'+
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 18"+
Water Supply: Individual (✓)
Public ( )

Installed by Baker Plumbing
w/ Backhoe
Winston Salem

IMPROVEMENTS PERMIT BY David R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE 5-17-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Hale DATE May 17, 79 PERMIT NO. 145

PHONE: Business _____ Home _____


LOCATION 150W TR on 1303 T.L. on 1428
2.3 mi. on Rt _____ S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 140 SECTION OR BLOCK NO. 11

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 186 AC.

Character & Porosity of Soil Cecil clay loam
Percolation Rate 80 mpi +
Topography 4-6%
Depth to Water Table 4' +
Rock or other impervious formations none els.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 150 Linear Ft. 250
Depth of Stone in Lines 18" +
Water Supply: Individual (✓)
Public ( )

Installed by Baker Plumbing
a Backhoe
Winston Salem

IMPROVEMENTS PERMIT BY David R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE 5-17-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold