IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

WNER OR CONTRACTOR H. L. Weeder DATE 3-12-74 PERMIT NO. _____

HONE: Business _____ Home 919-727-3937

OCATION 150 west TR on 1303 1½ mi TL. on 1428 1½ mi TR on Normandy Dr. 1st on right S. R. No. 1428

UBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


ouse (✓) Mobile Home ( ) Business ( ) Other _____

o. Bedrooms 3 No. Bathrooms 2

arbage Disposal Unit	Yes	(✓)	No	( )
uto. Dishwasher	Yes	(✓)	No	( )
uto. Wash. Machine	Yes	(✓)	No	( )
ite Suitable	Yes	(✓)	No	( )

ot Area over ½ acre

Character & Porosity of Soil ~~Clay~~ Sandy loam Porosity good
Percolation Rate not taken
Topography 20% slopes lot
Depth to Water Table
Rock or other impervious formations 5' to 15' to bedrock



Plot of System

Size of Tank 1250 Gals. – 12' long 5 wide
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Sam Oswalt
528-4883
Trautman

MPROVEMENTS PERMIT BY J. C. Moore

:OMMENTS: Trailer will be placed on lot first then house to be built later. Tank is 5½' under ground. put in like this To provide for plumbing in basement of House. Tank needs a manhole over clean-out to make it more accesible.

:ERTIFICATE OF COMPLETION BY J. C. Moore DATE 3-12-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold