VISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jon & Sandra Dobson APPLICANT: _____
ADDRESS: 1 Kenon Rd APPLICATION DATE: _____ DATE EVALUATED: 2/16/2001
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-12"	Brn SL GR FR						PS .25
		12"-24"	Rd/Brn C m SBK SS, SP, SE, FI-FR						
		24"-42"	Rd/Brn to Yel/Brn C m-w SBK to massive SS, SP, SE, FI						
		43"	Ht Chroma 2 Mottles						
2		0-12"	Brn SL GR FR						PS .25
		12"-26"	Rd/Brn C m-w SBK SS, SP, SE, FI-FR						
		26-40"	Rd/Brn to Yel/Brn C m-w SBK to massive SS, SP, SE, FI						
		40"	Ht Chroma 2 Mottles						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____