VISION OF ENVIRONMENTAL HEALTH:
I-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Tina Orr APPLICANT: _____
DDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/9/2001
OPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
CATION OF SITE: Kenway Loop PROPERTY RECORDED: _____
ATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
ALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
PE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
Initial	0-26"	Brw SCL	GR-wf SBK SS, SP, SE, FR					PS .3
Drain that was in middle rerooted to Left SL.	26-48"	Rd/Brw CL	wf SBK SS, SP, SE, FR					
	0-26"	Brw SCL	GR-wf SBK SS, SP, SE, FR					PS .25-.3
	26-48"	Brw C/CL	wf SBK SS, SP, SE, FI-FR					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
uilable Space (.1945)		
tem Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____