4638 38 2386

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR H. F. Hughs / Heritage DATE 8-20-76 PERMIT NO. _____

PHONE: Business _____ Home 528-1367


LOCATION 1303 N Turn on 1300 2nd Lot on Kennedy Drive 1/2 mi. on left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 47 SECTION OR BLOCK NO. 15

House ( ) Mobile Home ( ) Business ( ) Other Adding To Existing house

No. Bedrooms _____ No. Bathrooms _____

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No ( ) | Character & Porosity of Soil _____ |
| Auto. Dishwasher | Yes ( ) | No ( ) | Percolation Rate _____ |
| Auto. Wash. Machine | Yes ( ) | No ( ) | Topography Existing System |
| Site Suitable | Yes ( ) | No ( ) | Depth to Water Table _____ |
| Lot Area _____ | | | Rock or other impervious formations _____ |




Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 375
Depth of Stone in Lines 10"

Water Supply: Individual (X)
Public ( )

Installed by Sanitary
1968

The proposed / existing 24'x34' Garage addition does not appear to impact the existing septic system.
**NOTE: Must keep at least 25ft from well
Keep all Structures at least 5ft from septic

Maria Nelson REHS
Date: 12/17/2010
ICHD-Environmental Health Division

24'x34' Kenway LP

IMPROVEMENTS PERMIT BY _____

COMMENTS: System is adequate for additional

CERTIFICATE OF COMPLETION BY _____ DATE 8-24-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold