## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. E. Oates DATE Apr. 2, 1979 PERMIT NO. 81

PHONE: Business _____ Home _____

LOCATION 1303 T.L. on 1300 T.L. on Kenway (Kenway) Dr. #1398 T.L. on 1435


S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 33 SECTION OR BLOCK NO. 15

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes (✓) | No ( ) | Character & Porosity of Soil | clay loam |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | 60-80 min. |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | 6-10% |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | sink. |
| Lot Area 3/4 ac. | | | Rock or other impervious formations | none obs. |




Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Benny Myers

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hanson DATE Apr. 2, 1979

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold