IREDELL COUNTY HEALTH DEPARTMENT 4638395793

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Pittman DATE 7-6-84 PERMIT NO. 214

PHONE: Business _____ Home _____

LOCATION 1303 N TL on 1300 1st Rd Past church on TL (Bagley) 3/4 approx. 100 yds on left

SUBDIVISION NAME LAKE Norman S. R. No. _____ LOT NO. 27 SECTION OR BLOCK NO. 15


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3/4 acre

Character & Porosity of Soil clay loam
Percolation Rate soil borings
Topography 2% slope
Depth to Water Table 10' +
Rock or other impervious formations None



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines _____
Water Supply: Individual (✓) well next door
Public ( ) property line

Installed by Sam Oswalt 10-28-76

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

System Checked by J. C. Moore 10-28-76

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Existing system working OK at date of inspection

Road

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Charles K. Barnett & Fred Clemmer DATE 7-6-84

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold