1130

IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # ~~15579~~ 17484 PIN # 4638 42 2510 Martha DATE August 16, 2011

OWNER Bridgewater VI LLC APPLICANT: Samel Lancis PHONE: Home/Cell # Martha 704 235 3211 Business # 704-578-4951 (Saunders)

SITE ADDRESS Normandy Rd OWNER / APPLICANT ADDRESS PO Box 3608 Mooresville NC 28117

SITE DIRECTIONS 150 W TR Perth TL Normandy on left

SUBDIVISION Normandy Creek BLOCK / SECTION LOT # 3 LOT AREA 1.237 Ac. DESIGN FLOW 480 gpd L.T.A.R. @325 per plan

Septic Tank 1000 Gallons: STB 312 Date 5-26-11

Pump Tank 1000 Gallons: P T 253 Date 7-22-11

Pump Make Geotas Model WFO 712 H Serial #

No. Nitrification Fields: 1 No. Lines 4 Linear Feet 369

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: 25% Reduction Pump

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: Remove berms - some shaping needed. Supply line shall be min. 10' from swimming pool. Tanks or septic field shall be min. 15' from pool. 100' separation of well and septic system required

3/22/2012 Reviewed Floor plans & site plans, in compliance with original plan

*Note: Bonus Room must be unfinished

INITIAL SITE SKETCH

Provide orange fencing to protect septic area

See Plan from

Kathleen Saunders, LSS

Approved by ICHD

AS BUILT SKETCH

as per plan Noelectrical outlets & No A/C ducts.

5/31/12 Checked tanks, lines & set 2ft pressure Quick 4

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** with plat valid without expiration. ☒ ***IMPROVEMENT PERMIT*** with ~~plat valid without expiration~~ site plan valid 60 mo. ☐ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT–not to exceed 60 mo.

Owner / Applicant Signature: Kathleen Saunders Date 8-17-11

IMPROVEMENT PERMIT by: REHS Date 8-16-11

AUTHORIZATION TO CONSTRUCT by: REHS Date 3/22/12

Installed by: FJ Eavy

OPERATION PERMIT by: REHS Date 10/3/12

Existing System Inspected by: REHS Date

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant