10687

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dwight Sherrill DATE June 21, '90 PERMIT NO 2P-4-A-123

PHONE: Business _____ Home _____

LOCATION 150 W. TR 1303 (Perth) TL 1428 (Normandy) 1-1½ miles on Right S. R. No. _____

SUBDIVISION NAME COLET LAKE NORMAN LOT NO. 1095 SECTION OR BLOCK NO. 11

DW

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ PS Yes (✓) No ( )

Lot Area ~1 AC.

Drainfield Area

Character & Porosity of Soil LS clay


Percolation Rate 0.35

Topography ~4%

Depth to Water Table 44

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



1500 p.T.

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 1050 Linear Ft. 360 ✗

Depth of Stone in Lines 12"+

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: Drainfield installed in 30" trench. Linear footage increased to 435' total to get comparable footage for 36" wide trench.

~~Operation permit~~ CERTIFICATE OF COMPLETION BY [signature], EHS DATE 6-21-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold