13429

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Allen E Cook DATE 9/20/91 PERMIT NO. 2P-4-A-118

PHONE: Business _____ Home 892-3045

LOCATION Normandy Rd; Perth Rd, TL on Normandy Rd., 2 miles on ®

S. R. No. 1428


SUBDIVISION NAME CL+T LOT NO. 1094 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	P - c(s-sp)
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	3
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	>48"
Lot Area 20,000 FT²			Rock or other impervious formations	None observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

1000 Pump Tank

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3 @ 70' X 24"
Sq. Ft. X Linear Ft. 210
Depth of Stone in Lines N/A

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Lou Caputo

X 16" Prefabricated Panel Block System with pump.

IMPROVEMENTS PERMIT BY Wesley Sparks R.S.

COMMENTS: 1¼ PVC with one 3/16" hole per panel drilled in PVC. Gate valve at beginning of each lateral - 2' stand pipe at end of each lateral. Trenches no deeper than 30" to trench bottom. Contours are to be closely followed as shown on sketch.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold