4638450871

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William S. Smith DATE 8-7-78 PERMIT NO. 191

PHONE: Business _____ Home _____

LOCATION 1303 T2 on 1428 3/4 mi on right

_____ S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 81 SECTION OR BLOCK NO. 11

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil Sandy Clay Loam


Percolation Rate 60 min/in

Topography 8% Slope

Depth to Water Table 6' to 8'

Rock or other impervious formations None

Lot Area 3/4 acre



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by J.C. is Backhoe Service

IMPROVEMENTS PERMIT BY _____

COMMENTS: System Covered after 2 day of Rain Soil Wet

CERTIFICATE OF COMPLETION BY John Houston DATE 8-7-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold