IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gene Davis DATE 10-24-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1303 TL on 1301 atent TR 1st RL TL atent

SUBDIVISION NAME Lake Norman LOT NO. 14 SECTION OR BLOCK NO. 104 S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area .66 acres

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____

EXISTING System



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 16
Water Supply: Individual (✓)
Public ( )
next door

Installed by ?
1969

IMPROVEMENTS PERMIT BY _____

COMMENTS: System is adequate for addition

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-24-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold