IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 201619

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4638-52-2810

APPLICANT: Robert G. Gido APPLICANT ADDRESS: 173 N Audubon Ave Mooresville NC 28115

SITE ADDRESS: 110 Airplane Ct Mooresville NC 28117 PHONE: 704-604-6360 ALT. PHONE:

SITE DIRECTIONS: HWY 150 W, TR on Perth Rd, TL on Normandy Rd, TL on Airplane Ct

SUBDIVISION: Lake Norman Air Park SECTION: 7 LOT # 4 LOT AREA: 1.829 ac DESIGN FLOW: 720 gpd L.T.A.R.: 0.3

Septic Tank EXISTING 1500 (gal) STB Date
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 1 Linear Ft: 100
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☐ New System ☐ Repair ☑ Expansion System Type: I II (III) IV V VI
System Description: Gravity 25% Reduction
Repair System Description: LP PPRPS
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 6
☐ Business No. Persons 12
☑ Other No. Employees
☐ Slab ☐ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: * Airplane Hanger

INITIAL SITE SKETCH

SEE DESIGN BY SAME

Approved by ICHD

AS BUILT SKETCH

The proposed / existing POOL SHOWN ON ORIGINAL PERMIT addition does not appear to impact the existing septic system.
**NOTE:

Date: APPROVED APR 08 2014 R.S.
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 3/9/14 Installed by: Ground Breakers

IMPROVEMENT PERMIT by: Date: 2-19-14 OPERATION PERMIT by: Date: 3-27-14

AUTHORIZATION TO CONSTRUCT by: Date: 2-19-14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK