DEPARTMENT OF ENVIRONMENT, HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Donald Douthitt OWNER: ____ AGENT: ____ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 8/5/94
PROPOSED FACILITY: 4 bedroom SF Dwelling
PROPERTY SIZE: ____
LOCATION OF SITE: Lot 14, LN Airpark
WATER SUPPLY: On-Site Well ____ Comm. Well ____ Public ____ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	LS to SS 4-6%	0-10	SAB / CL	1:1 / fr			PS		.3
		10-24	SAB / C	1:1 / fi					
		24-46+	WK SAB / SIC	1:1 / fi					
2	LS to SS	0-9	SAB / CL	1:1 / fi fr			PS		.3
		9-28	SAB / C	1:1 / fi vfi					
		28-48	WK SAB / SICL	1:1 / fi					
3									
4									
5									

AVAILABLE SPACE (.1945): PSA SITE CLASSIFICATION (.1948): PSA SITE LONG-TERM ACCEPTANCE RATE .3
OTHER(S) PRESENT: ____
EVALUATED BY: ____
COMMENTS: Site very thick w/ underbrush - unable to determine if available space is sufficient for conventional system. There is enough space for PPBPS & repair.