DEPARTMENT OF ENVIRONMENT, HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MARK Mayerchak OWNER: ___ AGENT: ___ PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 3/20/96
PROPOSED FACILITY: 480 G.A.D.
PROPERTY SIZE: 1.6 AC
LOCATION OF SITE: Norwaday Rd. TL Outside Lp. lot on (R) corner
WATER SUPPLY: On-Site Well X Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring X Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	CV LS	0 - 5	sbk cl	1:1 FR S SP					
		6 - 16	FI sbk cl	FR S SP					
		17 - 26	VFI sbk L cl	FR SS SP					.3
		27 - 33	GR cl	FR SS NP					.35
		34 - 47	BR L	VFR SS NP					
2 TOWARD Gully	CV	0 - 4	sbk cl	FR SS SP					
		5 - 9	sbk w GR cl	FR SS SP					
		10 - 25	wk sbk c	FI S SP					.35
		26 - 35	sbk cl	FR SS SP					.3
		36 -	FI GR L	VFR SS NP					
3									
4									
5									

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE ___
EVALUATED BY: ___ OTHER(S) PRESENT: ___
COMMENTS: House not properly staked 3 sides only