IREDELL COUNTY HEALTH DEPARTMENT

13758 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Billy F. Overcash DATE 12/4/91 PERMIT NO. 2P-4-A-73

PHONE: Business _____ Home 855-1480

LOCATION Normandy Rd; Perth Rd. TL on Normandy Rd. to first paved drive on (R) S. R. No. _____

SUBDIVISION NAME Lake Norman Park LOT NO. 73 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil P - c (sl)
Percolation Rate 4
Topography 5-8%
Depth to Water Table > 48"
Rock or other impervious formations cobbly-stone 36"

Lot Area 20,000 FT²

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Size of Tank 1000 Septic Tank 1000 Pump Tank Gals.
Nitrification Field:
No. of Lines 3 @ 80' x 3'
Sq. Ft. 960 Linear Ft. 320
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: William F. Davis Jr.

IMPROVEMENTS PERMIT BY Wesley Parker R.S.

COMMENTS: Pressure conventional - 1½ PVC lines through gravel with 3/16" hole drilled on five foot centers. Gate valve at beginning of each line - 2' stand pipe at end of each line to balance the drainlines. Keep trenches shallow - no deeper than 36" to trench bottom.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold