IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR D. E Gatewood DATE 10-16-73 PERMIT NO. 275

PHONE: Business 1725-5381 Home

LOCATION 150 W TR on 1303 3 miles L on 1428 1 mi on right S. R. No. 1428

SUBDIVISION NAME Duke Power LOT NO. 81 SECTION OR BLOCK NO. 11


House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil soil type Porosity good
Percolation Rate Not taken
Topography Sloped to lake
Depth to Water Table 15' to lake level
Rock or other impervious formations none

Lot Area over ½ acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 561 Linear Ft. 204
Depth of Stone in Lines 12
Water Supply: Individual (✓)
Public ( )

Installed by F. J Ervin

IMPROVEMENTS PERMIT BY David Gabriel

COMMENTS: System was shorten from orginal lay-out due to way lot sloped off, the soil was good and extra stone was used to make system acceptable.

CERTIFICATE OF COMPLETION BY J. C. Moose DATE 11-2-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold