4638566616

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Pat Curry DATE 10-10-95 PERMIT NO. 224

PHONE: Business _____ Home _____

LOCATION 15 N west to SR on 1303 Turn left
on 2nd west left stay left on 1303 Pass on L on R S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 170 SECTION OR BLOCK NO. 14


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	( )	
Auto. Dishwasher	Yes	( )	No	( )	
Auto. Wash. Machine	Yes	( )	No	( )	
Site Suitable	Yes	( )	No	( )	

Lot Area Adequate

Character & Porosity of Soil Porosity good to fair Cowdeb & Clay soils
Percolation Rate 20 min
Topography 20 to 25% Slope
Depth to Water Table 4 to 5 ft. to rock
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public ( )

Installed by Sam Smith

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-10-95

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold