4638567471

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Howard Woodie DATE 9-10-85 PERMIT NO. 396

PHONE: Business _____ Home _____

LOCATION 150 (W) TR 1303 TL 1301 (Stumpy Creek Access Road) NC 2708 (Collingswood) S. R. No. _____


SUBDIVISION NAME LAKE NORMAN LOT NO. 68 SECTION OR BLOCK NO. 94 Stage Coach

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil		
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate		
Auto. Wash. Machine	Yes (X)	No ( )	Topography	EXISTING	
Site Suitable	Yes (X)	No ( )	Depth to Water Table		
Lot Area EXISTING			Rock or other impervious formations	System	

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines EXISTING
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual X
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY: _____

COMMENTS: EXISTING System working OK AT date of inspection, Do not set up Mobile Home over Drainfield

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Fred Clemmer DATE 9-10-85

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Howard Hinkle DATE 6-22-78 PERMIT NO. 143

PHONE: Business _____ Home 857 5025

LOCATION 203 to 72 to 201 on Rt 72 on right

S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 68 SECTION OR BLOCK NO. 4

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 1 acre


Character & Porosity of Soil Sandy Clay loam

Percolation Rate 45 min/in

Topography Slight slope

Depth to Water Table 6 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 1
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 24"

Water Supply: Individual (✓)
Public ( )

Installed by Tayco Concrete

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Bob Thornton DATE 6-22-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold