IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Davis DATE 8-12-77 PERMIT NO. 220

PHONE: Business _____ Home 535-0277

LOCATION 1303 N. To on 1301 1st left.
1st at Forks ½ mi on right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 69 SECTION OR BLOCK NO. 14


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil clay loam
Percolation Rate 60 min/inch
Topography 6% slope
Depth to Water Table 6+0 ft to lake level
Rock or other impervious formations none

Lot Area 1.8 acres



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 17"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-12-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold