DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: D. Fisher APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 5/19/98
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): ____ PROPERTY SIZE: ____
LOCATION OF SITE: Lot 22 Harborview III PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (1941) 1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	V w/o	0-6	gr SL/scl						B .3
		6-24	SAB rc	fr sl cl					
		24-60	M-wk SAB	P-vfr cl fr sp cl					
			w/ few mod gley/sep.						
2	V	0-30"	SAB rc/cl	fr sp cl					B .3
		pit had standing water in bottom at 30"							
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____
EVALUATED BY: ____
OTHER(S) PRESENT: ____

DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Nancy Foster
ADDRESS: _____
APPLICANT: _____
APPLICATION DATE: _____
DATE EVALUATED: 6-25-96
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 450
PROPERTY SIZE: _____
LOCATION OF SITE: Lot 22 Hurricane Section
PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	RS 2-4%	0-5	gr-sab w-bsl sl/sc fr						e3
		5-23	sab vfr	fi sp l-l					
		23-46	sasc vfr	fi sp l-l					
			few redox matrix						
2	RS 2-4%	0-7	gr-sab bsl sl/sc fr						e3
		7-23	sab vfr	fi sp l-l					
		23-46	sasc vfr	fi ss sp l-l					
			few redox matrix						
3	RS 2-4%	0-5	gr-sab bsl sl/sc fr						e3
		5-25	sab vfr	fi sp l-l					
		25-50	sasc vfr	fi sp l-l					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

Long Term Acceptance Rate for Evaluation