DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Stumpy Creek LLC
ADDRESS: _____
APPLICANT: _____
APPLICATION DATE: _____
DATE EVALUATED: 10/9/9
PROPOSED FACILITY: _____
PROPOSED DESIGN FLOW (.1949): 360gpd
PROPERTY SIZE: _____
LOCATION OF SITE: Harborview 9 Lot #10
PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR*	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Pit #1	0-5"	Brw SCL Gr		F-FR				.36
		5"-37"	Red-Brw C/CL w F SBK SS,SP,SH						36"
		37"	Red-Brw C/CL w Few to many SAP inclus						PS
2	Pit #2	0-10"	Brw SCL AR		Inclus				PS
		10"-39"	Red-Brw C/CL w Few SAP m-f SBK SE	SS,SP, FI-FR					.3 to 39"
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____