DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Michael Marrow APPLICANT: ___
ADDRESS: 106 Dearborn APPLICATION DATE: ___ DATE EVALUATED: 11/5/04
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: Clay T 14 Lot 11C PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed SE = Slightly Exp.

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTA
1A	Pit L 6%	0-6"	Rd/Brw CL	w/SBK SS,	SP, SE, FR				
		6-40	Rd SCL	m-wSBK	SS, SP, SE, FR				PS
		40-48	Brw CL	w/SBK SS, SP	SE, FR	48"	—	—	.3
					N/A				
2B	L 7%	0-3"	Brw SCL	GR SS, SP, SE, FR					
		3-6"	Rd/Brw CL	w/SBK SS, SP, SE, FR	N/A	48"	—	—	PS
		6-36"	Brw SCL	w/SBK					.3
		36-48"	Rd to Rd/Brw C	w/SBK					
3C	L 6%	0-8"	Brw SCL	SS, SP, SE, FR					
		8-38"	Rd CL/CL	m-w/SBK "	N/A	48"	—	—	PS
		38-48"	Rd/Brw CL/SCL	w/SBK					.3
4D	S 8%	0-8	Brw SCL	w/SBK SS, SP, SE, FR					
		8-32"	Rd C	mSBK "	N/A	48"	—	—	PS
		32"-40	Rd CL	w/SBK "					.3
		40-48	Rd to Rd/Brw C/SC	SS-SS, SP, SE					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Pump 25% Red	Pump 50% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): None
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Maina Dotson
OTHER(S) PRESENT: Ryan Keorey, Mike J. Marrow