IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dick Taylor DATE 2-13-75 PERMIT NO. 25

PHONE: Business 394-3933 Home 892-8903

LOCATION 150 west TR on 1303 Cross Lake Norman TL at end S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 51 SECTION OR BLOCK NO. 14


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 1 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area over ½ acre

Character & Porosity of Soil sandy clay loam (Porosity Fair)
Percolation Rate not taken
Topography 7 2% Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. ~~175~~ 125 Linear Ft. 250
Depth of Stone in Lines 17"
Water Supply: Individual (✓)
Public ( )

Installed by Blake Hyle
July 1973

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 2-13-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold