IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

11:30

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 157538 PIN # 4638672362 DATE 7-27-09

OWNER or APPLICANT John Edwards PHONE: Business 561 309 2307 Home: 561 313 8896

OWNER or APPLICANT ADDRESS 256 Collingswood Rd. Mooresville, NC 28117

LOCATION / DIRECTIONS Perth Rd TL Stumpy Creek TL on Collingswood at end on right #256

SUBDIVISION C & T BLOCK / SECTION 14 LOT # 1053 LOT AREA 1.25Ac DESIGN FLOW 240gpd L.T.A.R. 1.3+

Septic Tank 1000 Gallons: STB 794 Date 10-22-08 ☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

Pump Tank ____ Gallons: P T ____ Date ____ System Description: Gravity - 25% Reduction

Pump Make ____ Model ____ Serial # ____ Repair System Description: Same

Nitrification Field No Fields 1 No Lines 4 Linear Feet ~~200~~ 190 Maintenance Agreement Required ☐ YES ☒ NO

Trench Width 36" Max. Trench Bottom Depth 30" Gravel Depth N/A ☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 2 ☐ Business No. Persons ____ ☐ Other No. Employees ____ ☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private Shared ☐ Public ☐ Community

Comments / Conditions PL 307.76

Multi-port

Proposed Garage

INITIAL SITE SKETCH

Repair Area for Exist. MH.

Drive

Small Gulley (Properly Fill)

Large Gulley

Collingswood Road

Well

Existing MH

Exist Drainfield

PL 134.91

PL 242.04

Comments / Conditions Properly Fill "Small Gulley & Stay at least 5ft from it. If not properly filled must stay 15ft from Gulley. Keep Septic System at least 10ft from PL

AS BUILT SKETCH

Install ADS Arc 36

* Building (Garage) not started at time of inspection

Lake Norman

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: John Edwards Date 7/27/09

Improvement Permit by: Maria H. Dotson RS Date 7/27/09

Authorization to Construct by: Maria H. Dotson RS Date 7/27/09

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Larry Beam Grading

Operation Permit by: Maria H. Dotson RS Date: 8/19/2009

Existing System Inspected by: ____ Date: ____

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant